



कुळगांव बदलापूर नगरपरिषद



महानगरपालिका इमारत, म.ग.चे चौक रोड, म.ग.चे येथे (पूर्व) कुळगांव, तिन - ४०१५०३, ता. अहमदनगर जिल्हा, महाराष्ट्र.
E-mail - covid.kulgaonbada@maharashtra.gov.in, वेबसाइट - kham.gov.in

जावक क्र :- कु.ब.न.प / अग्नि / २४ / २०२५-२६

दिनांक :- १५ / ०४ / २०२५

प्रति,
प्राचार्य
रोझरी हायस्कूल,
यादव नगर, उल्हासनदी जवळ,
बदलापूर गांव रोड, बदलापूर पश्चिम.

विषय :- अग्निशमन विभागाचा ना - हरकत दाखला नुतनीकरण.


संदर्भ :- १) रोझरी हायस्कूल, प्राचार्य, रसिका पनिकर यांचा दि. १७ / ०३ / २०२५ रोजीचा अर्ज.
२) जा.क्र. कुबनप / अग्नि / ७६ / २०२३ - २४ दि. ०५ / १० / २०२३ अन्वये.
३) शासनमान्य लायसन्स अधिकरण मे. साईझिन्स फायर अँड सेफ्टी यांचे नमुना ' ब ' प्रमाणपत्र.
४) अग्निशमन विभागाने दिनांक. १५ / ०४ / २०२५ केलेली तपासणी व चाचणी.

महोदय,

कुळगांव बदलापूर नगरपरिषद हद्दीतील बदलापूर पश्चिम मोजे बदलापूर गांव रोड, विभागातील स.नं. १९० हिस्सा नं. ८ क १ व ९ या भूखंडावर बांधलेल्या तळ + १ मजलीच्या दोन शैक्षणिक इमारतीतील असलेल्या रोझरी हायस्कूलमध्ये लावलेल्या आग प्रतिबंधक उपाययोजनेच्या दृष्टीने पाहणी केली असता तपासणी दिवशी यंत्रणा लावल्याचे व कार्यन्वित असल्याचे खालील अटी शर्ती अधीन राहून दाखल्याचे नुतनीकरण करून देण्यात येत आहे.

- १) शाळेसाठी आवश्यक त्या शासकीय / निमशासकीय परवानगी घेण्याची जबाबदारी शाळा व्यवस्थापनाची असेल.
- २) शाळेत लावलेल्या आग प्रतिबंधक यंत्रणेची नियमित देखभाल दुरुस्ति ठेवावी.
- ३) शाळेतील अग्निशमन यंत्रणा हाताळणीचे प्रशिक्षण सर्व स्टॉफला यंत्रणा बसविणाऱ्या एजन्सी मार्फत द्यावे.
- ४) प्रत्येक वर्षी जानेवारी व जुलै महिन्यात लायसन्स एजन्सी मार्फत अग्निशमन यंत्रणेची तपासणी व चाचणी करून नमुना व प्रमाणपत्र घेणे बंधनकारक आहे.
- ५) सुरक्षा कॅबिन मध्ये महत्वाचे दूरध्वनी क्र. ठळक अक्षरात लावावे.
- ६) फायर पंप Attenuate विद्युत पुरवठा जोडण्यास यावा.
- ७) वर्षातून किमान एकदा Mock drill चे आयोजित करावे.
- ८) गच्चीवरील फायर सिस्टमचा पाण्याचा मुख्य वाल्व सदैव चालू स्थितीत ठेवावा.
- ९) शाळेच्या इमारतीत किचन / पॅन्ट्री करू नये.
- १०) सदरचा दाखला दिलेल्या तारखेपासून १ वर्षांपुरता मर्यादित असून दरवर्षी दाखल्याचे नुतनीकरण करणे बंधनकारक आहे.
- ११) स्थळाचे एकूण क्षेत्रफळ ----- स्केअरफुट असून नुतनीकरण नाहरकत दाखला फी रु. ५०००/- पावती क्र. ५३२२१ अन्वये दि. १५ / ०४ / २०२५ भरण्यात आली आहे.




अग्निशमन अधिकारी
कुळगांव बदलापूर नगरपरिषद
कुळगांव

Fire Safety Certificate / Renewal Letter

(From Kulgaon Badlapur Municipal Council)

Date: 15/04/2024

Reference No.: Fire / 22 / 2024-25

To,
The Principal,
Rosary High School,
Yadav Nagar, near Ulhasnadi,
Badlapur Gaon Road, Badlapur (West)

Subject:

Renewal of Fire Department No Objection Certificate (NOC)

Reference:

1. Application submitted by Rosary High School dated 19/03/2024
2. Previous Fire NOC issued on 04/10/2023
3. Standard Fire & Safety compliance certificate (Form 'B')
4. Inspection conducted by Fire Department on 15/04/2024

Respected Sir/Madam,

Following the inspection conducted by the Fire Department of Kulgaon Badlapur Municipal Council, the fire safety arrangements installed in your school building (Ground + 2 floors) located at Badlapur (West) have been verified.

Based on the inspection and subject to compliance with the following conditions, the **Fire NOC is hereby renewed.**

Conditions:

1. The school management shall obtain all necessary government and local authority permissions.
2. Fire safety equipment installed in the school must be **regularly maintained and kept functional.**
3. All staff must be **trained in handling fire safety equipment through authorised agencies.**
4. Fire safety systems must be **inspected annually (Jan-June period)** and certified by authorised agencies.
5. Important emergency contact numbers must be **clearly displayed** in the premises.
6. Fire pump must be connected to an **alternate power supply.**
7. At least **one mock drill per year** must be conducted.
8. Water supply valves of the fire system must be kept **operational at all times.**

9. No obstruction/storage should be done in school passages or premises that may hinder safety.
10. The renewal is valid for **one year from the date of issue** and must be renewed annually.
11. The premises area is recorded as 16470 sq. ft.
12. Renewal fee of ₹5000 has been paid (Receipt No. 43232 dated 15/04/2024).

Issued by:
 Fire Officer
 Kulgaon Badlapur Municipal Council
 (Official Seal & Signature)

Subject:

Renewal of Fire Department No Objection Certificate (NOC)

Reference:

1. Application submitted by Rosary High School dated 19/03/2024
2. Previous Fire NOC issued on 04/10/2023
3. Standard Fire & Safety compliance certificate (Form 'B')
4. Inspection conducted by Fire Department on 15/04/2024

Respected Sir/Madam,

Following the inspection conducted by the Fire Department of Kulgaon Badlapur Municipal Council, the fire safety arrangements installed in your school building (Ground + 2 floors) located at Badlapur (West) have been verified. Based on the inspection and subject to compliance with the following conditions, the Fire NOC is hereby renewed.

Conditions:

1. The school management shall obtain all necessary government and local authority permissions.
2. Fire safety equipment installed in the school must be regularly maintained and kept functional.
3. All staff must be trained in handling fire safety equipment through authorized agencies.
4. Fire safety systems must be inspected annually (Jan-June period) and certified by authorized agencies.
5. Important emergency contact numbers must be clearly displayed in the premises.
6. Fire pump must be connected to an alternate power supply.
7. At least one mock drill per year must be conducted.
8. Water supply valves of the fire system must be kept operational at all times.